



FM Approvals  
1151 Boston Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

**ExFm-XBab. XENON BEACON**

XP/II/1/BCD/T4 Ta = 55°C; I/1/Ex d IIC/T4 Ta = 55°C; DIP/II,III/1/EFEG/T4 Ta = 55°C; Type 4, IP66

a = Power consumption 5, 11 or 20 Joules

b = Supply Voltage 24VDC, 115VAC or 230VAC

### Equipment Ratings:

Explosionproof for Class I, Division 1, Groups B, C and D; suitable for Class II, Division 1, Groups E, F and G, and suitable for Class III, Division 1 hazardous locations; flameproof for Class I, Zone 1, Ex d IIC T4, Ta -20°C to +55°C; indoor and outdoor (Type 4 / IP66).

### FM Approved for:

Seagull Safety (Singapore) Pte Ltd.  
1 Genting Link, #07- 06 Perfect Industrial Building,  
Singapore 349518

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

CSA-C22.2 No. 0.4-04	2004
CSA-C22.2 No. 0.5	2003
CSA-C22.2 No. 25	1966
CSA-C22.2 No. 30	2003
CSA-C22.2 No. 94-M91	2001
CSA-C22.2 No. 142-M1987	2004
CAN/CSA E60079-0	2006
CAN/CSA E60079-1	2006
CSA-C22.2 No. 60529	2005

Original Project ID: 3028214C

Approval Granted: *October 15, 2008*

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

  
\_\_\_\_\_  
J. E. Marquedant  
Group Manager, Electrical

*15 October 2008*  
\_\_\_\_\_  
Date