



FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

ExFm-XBab. XENON BEACON

XP//I/1/ABCD/T4 Ta = 55°C; I/1/AEx d IIC/T4 Ta = 55°C; DIP//I,III/1/EFG/T4 Ta = 55°C; Type 4, IP66

a = Power consumption 5, 11 or 20 Joules

b = Supply Voltage 24VDC, 115VAC or 230VAC

Equipment Ratings:

Explosionproof for Class I, Division 1, Groups A, B, C and D; dust-ignitionproof for Class II & III, Division 1, Groups E, F and G hazardous (classified) locations; flameproof for Class I, Zone 1, AEx d IIC T4, Ta -20°C to +55°C; indoor and outdoor (Type 4 / IP66).

FM Approved for:

Seagull Safety (Singapore) Pte Ltd.
1 Genting Link, #07- 06 Perfect Industrial Building,
Singapore 349518

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3615	2006
Class 3810	2005
ANSI/ISA 60079-0	2005
ANSI/ISA 60079-1	2005
ANSI/NEMA 250	2003
ANSI/IEC 60529	2004

Original Project ID: 3028214

Approval Granted: *October 15, 2008*

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC


J. E. Marquedant

Group Manager, Electrical

15 October 2008
Date